

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 4140-0127:104

Page 1 of 1

**CATEGORY:** Panic Hardware

**LISTEE:** Detex Corp., 302 Detex Drive, New Braunfels, TX 78130  
Contact: Greg Drake (830) 629-2900

**DESIGN:** Model ECL-8030 surface mounted rim type panic hardware. Unit employs an integral alarm which will sound when the bar is pushed. When the system is activated, it is intended to monitor against unauthorized egress of persons and allow exiting within 15 seconds. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number and UL label.

**APPROVAL:** Listed as panic hardware for use on non-rated single swinging doors to provide a locking means and prevent unauthorized use of the door. Authority having jurisdiction should be consulted prior to installation.

07-18-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**MAY 14, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager